

APPENDIX B

Toronto and Region Conservation Authority Stormwater Management Criteria and Requirements

Quantity Control

- 2-100 Post to Pre-development for sites with drainage areas less than 5 hectares.
- Don River Unit Release Rates for drainage areas greater than 5 hectares.

Quality Control

- Enhanced Level (80 % Total Suspended Solid Removal).

Erosion Control

- For a 25 mm event, it must be released over 48 hours for sites greater than 5 hectares.

Water Balance

- Detain a rainfall depth of 5 mm from all impervious areas.